

STEEL CAP-FLUSH WELDED
(10 GAUGE-3" DIA.)


SCHEDULE 40 GALVANIZED
3" DIA. STEEL PIPE

LUMINOUS YELLOW

ALL OTHER EXPOSED
METAL TO BE
PAINTED BLUE

GROUND SURFACE

CONCRETE
ENCASEMENT



DETAIL OF LETTERING

DETAIL OF MARKER POST

| | | | | | |
|--------------------|-------------|-----|-----|-----|------|
| C | | | | | |
| B | | | | | |
| A | | | | | |
| | DESCRIPTION | DRW | CKD | APP | DATE |
| REVISIONS | | | | | |
| DRAWN BY: S.D.A. | | | | | |
| CHECKED BY: S.D.A. | | | | | |
| APPROVED: | | | | | |

**MARKER,
APPURTENANCE,
TRANSMISSION
MAIN**

SCALE: NONE

CITY OF DETROIT
WATER AND SEWERAGE
DEPARTMENT
ENGINEERING
DIVISION

SHEET 1 OF 1

DWG No. 02620-16