



METER/VALVE/PIPE SIZE (A)	WALL SIDE (B)	OPEN SIDE (C)	END WALLS (D)	FLOOR (E)	FLOOR (F)
≤ 1 INCH	N/A, USE WABASH BOX				
1½-6 INCHES	14 INCHES	24 INCHES	14 INCHES	≥ 6 INCHES	24-36 INCHES
8-12 INCHES	24 INCHES	36 INCHES	14 INCHES	≥ 6 INCHES	24-36 INCHES
≥ 14 INCHES	36 INCHES	36 INCHES	14 INCHES	≥ 6 INCHES	24-36 INCHES

- * BY-PASS PIPING MAY BE PLACED ON INTERIOR OF VAULT (NOT SHOWN).
- * USE BANANA SCREEN AS SHOWN IN VAULTS WITH LIMITED SPACE. USE REGULAR SIZE SCREENS ELSEWHERE.

SEE "STANDARD METER VAULT NOTES" FOR ADDITIONAL INFORMATION.

C					
B					
A					
	DESCRIPTION	DRW	CKD	APP	DATE
REVISIONS					
DRAWN BY: S.D.A.					
CHECKED BY: S.D.A.					
APPROVED:					

**METER VAULT,
METAL, SMALL**

SCALE: NONE

CITY OF DETROIT
WATER AND SEWERAGE
DEPARTMENT
ENGINEERING
DIVISION

SHEET 1 OF 2

DWG No. 13400-04