

STANDARD SPECIFICATIONS

REFERENCE: UL 62, UL 1277.

CONDUCTOR: 16 AWG (1.5 mm<sup>2</sup>), 7-strand, concentric-lay, uncoated copper. Maximum operating temperature 90°C dry, 75°C wet.

INSULATION: Polyvinyl chloride, not less than 15 mils (380 μm) average thickness; 13 mils (330 μm) minimum thickness, UL 62, Type TFN.

LAY: Twisted pair with 1-1/2 inch to 2-1/2 inch (38.10 mm – 63.5 mm) lay.

SHIELD: Cable assembly, combination aluminum-polyester tape and 7-strand, 20 AWG (0.5 mm<sup>2</sup>) minimum size, tinned copper drain wire, shield applied to achieve 100 percent cover over insulated conductors.

JACKET: Conductor: Nylon, 4 mils (100 μm) minimum thickness, UL 62.  
Cable assembly: Black, flame-retardant polyvinyl chloride, UL 1277, applied over tape wrapped cable core.

CONDUCTOR IDENTIFICATION: One conductor black, one conductor white, one conductor red.

FACTORY TESTS: Insulated conductors shall meet the requirements of UL 62 for Type TFN. Assembly jacket shall meet the requirements of UL 1277. Cable shall meet the vertical-tray flame test requirements of UL 1277.

Cable Details

	Assembly Jacket Thickness *		Maximum Outside Diameter	
	in.	μm	in.	mm
Single Triad	0.045	1140	0.35	8.87

\*The average thickness shall be not less than that indicated above. The minimum thickness shall be not less than 80 percent of the value indicated above.

A durable marking shall be provided on the surface of the cable at intervals not exceeding 24 inches (600 mm). Marking shall include manufacturer's name, Type TC, Type TFN, conductor size, single triad, and voltage class.

C						<b>600 Volt, Single Triad, Shielded Instrument Cable (600-SINGLE-TRIAD-SH-INSTR)</b>	CITY OF DETROIT WATER AND SEWERAGE DEPARTMENT ENGINEERING DIVISION
B							
A							
	DESCRIPTION	DRW	CKD	APP	DATE		
REVISIONS							
DRAWN BY: B & V						SCALE: NONE	SHEET 1 OF 1
CHECKED BY: S.D.A.							16050-5
APPROVED:							DWG No.